

### CLIENT AND LOCATION DETAILS

IDS 1-10-2010  
TRAFFORD PARK

113 ITEMS

Room ID: WORKSHOP

### TEST RESULTS

Asset ID	Description	Test Date	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Extn.	Flash	Status
0006891751	110V LEAD	01/10/2010	Pass	0.185	-	-	>50	-	-	Pass	-	Pass
0006891752	110V LEAD	01/10/2010	Pass	0.171	-	-	>50	-	-	Pass	-	Pass
0006891753	110V LEAD	01/10/2010	Pass	0.152	-	-	>50	-	-	Pass	-	Pass
0006329836	110V ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.351	0	Skip	-	Pass
0006891754	110V GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.215	0	Skip	-	Pass
0006379017	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.184	0	Skip	-	Pass
0006329835	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.143	0	Skip	-	Pass
0006329834	110V TRANSFORMER	01/10/2010	Pass	0.071	-	-	>50	0	0	Skip	-	Pass
0006329842	110V TRANSFORMER	01/10/2010	Pass	0.074	-	-	>50	0	0	Skip	-	Pass
0006329841	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.121	0	Skip	-	Pass
0006329840	GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.201	0	Skip	-	Pass
0006311029	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.114	0	Skip	-	Pass
0006691755	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.451	0	Skip	-	Pass
0006691756	110V LEAD	01/10/2010	Pass	0.141	-	-	>50	-	-	Pass	-	Pass
0006329501	110V LEAD	01/10/2010	Pass	0.158	-	-	>50	-	-	Pass	-	Pass
0005049424	GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.158	0	Skip	-	Pass
0006691757	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.112	0	Skip	-	Pass
0006691758	110V LEAD	01/10/2010	Pass	0.194	-	-	>50	-	-	Pass	-	Pass
0006891759	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.102	0	Skip	-	Pass
0006891760	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.547	0	Skip	-	Pass
0006891761	110V TRANSFORMER	01/10/2010	Pass	0.077	-	-	>50	0	0	Skip	-	Pass
0006329823	GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.105	0	Skip	-	Pass
0006891762	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.655	0	Skip	-	Pass
0006891763	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.108	0	Skip	-	Pass
0003749846	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.188	0	Skip	-	Pass
0006691764	110 EXT LEAD	01/10/2010	Pass	0.115	-	-	>50	-	-	Pass	-	Pass
0006691765	110V LEAD	01/10/2010	Pass	0.157	-	-	>50	-	-	Pass	-	Pass
0006691766	110V LEAD	01/10/2010	Pass	0.197	-	-	>50	-	-	Pass	-	Pass
0006691767	110V TRANSFORMER	01/10/2010	Pass	0.070	-	-	>50	0	0	Skip	-	Pass
0006691768	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.579	0	Skip	-	Pass
0006691769	110V EXT LEAD	01/10/2010	Pass	0.121	-	-	>50	-	-	Pass	-	Pass
0006691770	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.114	0	Skip	-	Pass
0006691771	BATTERY CHARGER	01/10/2010	Pass	-	-	-	>50	0	0	Skip	-	Pass
0006329995	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.118	0	Skip	-	Pass
0006691772	110V TRANSFORMER	01/10/2010	Pass	0.081	-	-	>50	0	0	Skip	-	Pass
0006691773	GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.256	0	Skip	-	Pass
0006691774	110V LEAD	01/10/2010	Pass	0.180	-	-	>50	-	-	Pass	-	Pass
0006691775	110V LEAD	01/10/2010	Pass	0.173	-	-	>50	-	-	Pass	-	Pass


### CONTRACTOR DETAILS

MJM ENERGY & SAFETY SERVICES  
WELLINGTON TERRACE  
252 WELLINGTON ROAD SOUTH  
STOCKPORT

SK2 6ND

Tester Name P JOHNSON  
Qualifications ELECTRICIAN  
Position ELECTRICIAN

Signature



### CLIENT AND LOCATION DETAILS

IDS 1-10-2010  
TRAFFORD PARK

Room ID: WORKSHOP

### TEST RESULTS


Asset ID	Description	Test Date	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Extn.	Flash	Status
0006691776	110V LEAD	01/10/2010	Pass	0.187	-	-	>50	-	-	Pass	-	Pass
0006329510	110V LEAD	01/10/2010	Pass	0.162	-	-	>50	-	-	Pass	-	Pass
0006691777	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.125	0	Skip	-	Pass
0006329504	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.114	0	Skip	-	Pass
0006691778	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.854	0	Skip	-	Pass
0006329884	110V TRANSFORMER	01/10/2010	Pass	0.062	-	-	>50	0	0	Skip	-	Pass
0006329879	110V LEAD	01/10/2010	Pass	0.199	-	-	>50	-	-	Pass	-	Pass
0006691779	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.118	0	Skip	-	Pass
0006329901	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.758	0	Skip	-	Pass
0006311016	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.131	0	Skip	-	Pass
0006329876	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.115	0	Skip	-	Pass
0006329508	CIRCULAR SAW	01/10/2010	Pass	-	-	-	>50	0.352	0	Skip	-	Pass
0006329894	110V LEAD	01/10/2010	Pass	0.152	-	-	>50	-	-	Pass	-	Pass
0006329874	110V LEAD	01/10/2010	Pass	0.189	-	-	>50	-	-	Pass	-	Pass
0006691780	110V LEAD	01/10/2010	Pass	0.169	-	-	>50	-	-	Pass	-	Pass
0006329890	GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.251	0	Skip	-	Pass
0006691781	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.502	0	Skip	-	Pass
0006511238	110V TRANSFORMER	01/10/2010	Pass	0.078	-	-	>50	0	0	Skip	-	Pass
0006691782	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.511	0	Skip	-	Pass
0006691783	GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.121	0	Skip	-	Pass
0006691784	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.085	0	Skip	-	Pass
0005049367	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.101	0	Skip	-	Pass
0006691785	GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.221	0	Skip	-	Pass
0004607712	110V TRANSFORMER	01/10/2010	Pass	0.084	-	-	>50	0	0	Skip	-	Pass
0006691786	110V LEAD	01/10/2010	Pass	0.201	-	-	>50	-	-	Pass	-	Pass
0006691787	110V LEAD	01/10/2010	Pass	0.194	-	-	>50	-	-	Pass	-	Pass
0006691788	110V LEAD	01/10/2010	Pass	0.179	-	-	>50	-	-	Pass	-	Pass
0006691789	110V TRANSFORMER	01/10/2010	Pass	0.071	-	-	>50	0	0	Skip	-	Pass
0006691790	GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.302	0	Skip	-	Pass
0006691791	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.158	0	Skip	-	Pass
0006691792	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.418	0	Skip	-	Pass
0006691793	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.101	0	Skip	-	Pass
0006329896	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.612	0	Skip	-	Pass
0006311038	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.108	0	Skip	-	Pass
0006691794	110V BREAKER	01/10/2010	Pass	-	-	-	>50	0	0	Skip	-	Pass
0006691795	415V LEAD	01/10/2010	Pass	-	-	-	-	-	-	Skip	-	Pass
0006691796	415V FLOOR SAW	01/10/2010	Pass	-	-	-	-	-	-	Skip	-	Pass
0006691797	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.118	0	Skip	-	Pass

### CONTRACTOR DETAILS

MJM ENERGY & SAFETY SERVICES  
WELLINGTON TERRACE  
252 WELLINGTON ROAD SOUTH  
STOCKPORT

Tester Name P JOHNSON  
Qualifications ELECTRICIAN  
Position ELECTRICIAN

Signature



### CLIENT AND LOCATION DETAILS

 IDS  
 TRAFFORD PARK

1-10-2010

Room ID: WORKSHOP

### TEST RESULTS

Asset ID	Description	Test Date	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Extn.	Flash	Status
0006329513	110V LEAD	01/10/2010	Pass	0.135	-	-	>50	-	-	Pass	-	Pass
0006691798	110V LEAD	01/10/2010	Pass	0.188	-	-	>50	-	-	Pass	-	Pass
0005049439	JIGSAW	01/10/2010	Pass	-	-	-	>50	0.321	0	Skip	-	Pass
0006329506	JIGSAW	01/10/2010	Pass	-	-	-	>50	0.302	0	Skip	-	Pass
0006691799	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.221	0	Skip	-	Pass
0003741980	110V TRANSFORMER	01/10/2010	Pass	0.080	-	-	>50	0	0	Skip	-	Pass
0006691800	110V LEAD	01/10/2010	Pass	0.197	-	-	>50	-	-	Pass	-	Pass
0006691801	110V LEAD	01/10/2010	Pass	0.168	-	-	>50	-	-	Pass	-	Pass
0006691802	240V VACUUM	01/10/2010	Pass	-	-	-	>50	0.689	0	Skip	-	Pass
0006329517	110V LEAD	01/10/2010	Pass	0.158	-	-	>50	-	-	Pass	-	Pass
0006329518	110V LEAD	01/10/2010	Pass	0.188	-	-	>50	-	-	Pass	-	Pass
0006329502	110V LEAD	01/10/2010	Pass	0.155	-	-	>50	-	-	Pass	-	Pass
0006691803	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.187	0	Skip	-	Pass
0006329514	110V TRANSFORMER	01/10/2010	Pass	0.078	-	-	>50	0	0	Skip	-	Pass
0006311041	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.203	0	Skip	-	Pass
0006691804	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.651	0	Skip	-	Pass
0006691805	GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.289	0	Skip	-	Pass
0006691806	110V LEAD	01/10/2010	Pass	0.177	-	-	>50	-	-	Pass	-	Pass
0003966957	110V LEAD	01/10/2010	Pass	0.180	-	-	>50	-	-	Pass	-	Pass
0006329515	110V TRANSFORMER	01/10/2010	Pass	0.088	-	-	>50	0	0	Skip	-	Pass
0006691807	110V LEAD LAMP	01/10/2010	Pass	0.086	-	-	>50	0.088	0	Skip	-	Pass
0006329800	PISTOL DRILL	01/10/2010	Pass	-	-	-	>50	0.151	0	Skip	-	Pass
0006691808	CHOP SAW	01/10/2010	Pass	-	-	-	>50	0.389	0	Skip	-	Pass
0006691809	ANGLE GRINDER	01/10/2010	Pass	-	-	-	>50	0.587	0	Skip	-	Pass
0004680728	SDS PLUGS DRILL	01/10/2010	Pass	-	-	-	>50	0.105	0	Skip	-	Pass
0006329503	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.203	0	Skip	-	Pass
0003749636	SDS DRILL	01/10/2010	Pass	-	-	-	>50	0.158	0	Skip	-	Pass
0006329897	GRINDETTE	01/10/2010	Pass	-	-	-	>50	0.197	0	Skip	-	Pass
0006329526	STEAM CLEANER	01/10/2010	Pass	-	-	-	>50	0.412	0	Skip	-	Pass
0006691810	110V VACUUM	01/10/2010	Pass	-	-	-	>50	0.725	0	Skip	-	Pass
0006691811	FRIDGE	01/10/2010	Pass	0.089	-	-	>50	0.012	0	Skip	-	Pass
0004660738	MICROWAVE	01/10/2010	Pass	0.071	-	-	>50	0.984	0	Skip	-	Pass
0006691812	TOASTER	01/10/2010	Pass	0.079	-	-	>50	0.775	0	Skip	-	Pass
0006691813	BATTERY CHARGER	01/10/2010	Pass	-	-	-	>50	0	0	Skip	-	Pass
0006691814	KETTLE	01/10/2010	Pass	0.062	-	-	>50	1.859	0	Skip	-	Pass
0006691815	STEREO	01/10/2010	Pass	-	-	-	>50	0	0	Skip	-	Pass
0006691816	STEREO	01/10/2010	Pass	-	-	-	>50	0	0	Skip	-	Pass

### CONTRACTOR DETAILS

 MJM ENERGY & SAFETY SERVICES  
 WELLINGTON TERRACE  
 252 WELLINGTON ROAD SOUTH  
 STOCKPORT

 Tester Name P JOHNSON  
 Qualifications ELECTRICIAN  
 Position ELECTRICIAN

Signature

